

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7272-0447:128 Page 1 of 1

CATEGORY: Smoke Detectors/Photoelectric

LISTEE: ESL/Sentrol Inc., 12345 SW Leveton Dr., Tualatin, OR 97062
Contact: Gene Hukkanen (503) 691-7369

DESIGN: Model 429-AT, -C, -CAD, -CT, -CTAD, -CRT, -CST or -CSST; and Model 449-AT, -C, -CT, -CRT, -CSRH, -CSRT, -CS(S)T, -CSSTE, -CSTE, -CTE, -CLT or -CSLT photoelectric type smoke detectors. Units may employ an integral heat sensor (135° F fixed temperature and 15° F per minimum rate of rise) and sounding device. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical/temperature rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with separately listed electrically compatible fire alarm control units except *Models 429CAD and 429CTAD are intended for use only with ADT Model Focus 200 (CSFM Listing No. 7165-0085:171).

NOTE: Integral heat sensor and sounder are supplemental to smoke detector.

*Rev. 07-17-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager